

CERTIFICATE OF COMPLIANCE

Certificate Number **20060203-R4349**
Report Reference **2006 February 3**
Issue Date **2006 February 3**



Issued to: **Premier Steel Doors & Frames**
2840 Hwy 165 N
Monroe, LA 71203 USA

*This is to certify that
representative samples of*

Swinging Type Fire Doors

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate*

Standard(s) for Safety: **ANSI/UL 10B - 9th Edition**
ANSI/UL 10C - 1st Edition

Additional Information: **See addendum for Classifications**

Only those products bearing the UL Classification Mark should be considered
as being covered by UL's Classification and Follow-Up Service

The UL Classification Mark includes UL and a circle symbol:  with the
word "CLASSIFIED" (as shown), control number (may be alphanumeric)
assigned by UL, a statement to indicate the extent of UL's evaluation of the
products, and the product category name (product identity) as indicated in
the appropriate UL Directory.

Look for the UL Classification Mark on the product.

Issued by

Mona Couloute
Underwriters Laboratories Inc.

Reviewed by: 
Matthew Schumann
Underwriters Laboratories Inc.

CERTIFICATE OF COMPLIANCE

Certificate Number **20060203-R4349**
Report Reference **2006 February 3**
Issue Date **2006 February 3**



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Hollow Metal or Steel Covered Composite,
3 HR Single/Pair With Astragal
Single Point Lock/Flush Bolts
3 HR Single or Pair With Astragal
Rim, Mortise/Vertical Rod F.E.H.
3 HR Single/Pair With Astragal

Hollow Metal,
1-1/2 Single or Pair Without Astragal
Rim, Mortise/Vertical Rod F.E.H.
1-1/2 Pair Without Astragal
Open Back Strike Provided
1-1/2 Double Egress With Astragal
Vertical Rod/Vertical Rod F.E.H.
1-1/2 Door With Automatic Louver
3 HR Double Egress With Astragal
Vertical Rod/Vertical Rod F.E.H.

Steel Covered Composite,
3 HR 250 F Temperature Rise Door

Composite and hollow-metal type doors bearing the 1-1/2 HR Classification Marking for use with Listed transom panel Listed by the manufacturer under Door and Window Frames.

Hollow metal type doors bearing the 1-1/2 HR Classification Marking for use with Listed multiple opening frame design Listed by the manufacture under Door and Window Frames.

Issued by
Mona Couloute
Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:


Matthew Schumann
Underwriters Laboratories Inc.